



CMD 23-M36.5A

Date: 2023-12-05

File / dossier : 6.02.04

Edocs pdf : 7181450

## **Supplementary Information**

**Presentation from  
Paul Sedran, RESD Inc.**

## **Renseignements supplémentaires**

**Présentation de  
Paul Sedran, RESD Inc.**

---

Regulatory Oversight Report for  
Canadian Nuclear Power Generating  
Sites: 2022 and Mid-term update for  
Ontario Power Generation's Pickering  
Nuclear Generating Station

---

Rapport de surveillance réglementaire  
des sites de centrales nucléaires au  
Canada : 2022 et Rapport de mi-parcours  
d'Ontario Power Generation pour la  
centrale nucléaire de Pickering

Commission Meeting

Réunion de la Commission

**December 13 and 14, 2023**

**13 et 14 décembre 2023**

# Review of Submissions for the PNGS Midterm Review and the CNSC ROR for 2023

P.J. Sedran, M.Eng, P. Eng.  
Mech. Eng. Consultant

December 13<sup>th</sup>, 2023


# Presentation Contents

1. Introduction – Components of the review
2. Main Finding from the Review of the PNGS Midterm Report:  
Calibration of CT-PT Gap Measurements
  - 2.1 Gap Calibration Procedure
  - 2.2 Validity of Gap Calibration – CT ID profiles
  - 2.3 Effect of Gap Calibration on CT-PT time-to-contact
3. Conclusions

# 1. Introduction – Components of the Review


1. OPG's Midterm Report on Licensing Activities for PNGS was reviewed.
2. The CNSC ROR was reviewed
3. For 1. the main emphasis was a finding on CT-PT gap calibration

# 2.1 CT-PT Gap Calibration Procedure




## 2.2 Validity of Gap Calibration

CT ID Profiles from the 2005 Inspection of Fuel Channel G-2 H14 with No Gap Calibration




CT ID Profiles from the 2004 Inspection of Fuel Channel PLGS F06 with Gap Calibration




## 2.2 Validity of Gap Calibration Continued

CT ID Profiles from the Gauging Measurements of  
The CT Removed from Fuel Channel P4M11



## 2.3 Effect of Gap Calibration on CT-PT time-to-contact

As Measured and Calibrated Gaps for G2K07 versus Distance from the Inspection Face CTS



Calibration	x (mm)	EFPH (h)	Measured Gap (mm)	Fuelled Gap at x (mm)	Time-to- contact at x (EFPH)
None	1870.4	161000	3.430	3.427	417125
Calibrated	1897.9	161000	4.140	4.137	622061



### 3. Conclusions

1. In-service CTs are expected to have a nearly uniform mean CT ID profile over the length of the CT
2. With as-measured gap profiles, CT ID values conform to condition 1.
3. With gap calibration, CT ID values do not conform to condition 1.
4. The above indicate that gap calibration may be technically incorrect and further investigation will be required to make the finding conclusive.
5. With gap calibration, time-to-contact predictions may be anti-conservative.