



Pickering Nuclear Generating Station Licence Renewal

Commission Hearing (Part 1), April 4, 2018

CMD 18-H6.A



CNSC Staff Presentation

A grayscale photograph of a nuclear power plant facility situated along a body of water. The plant features several large, rounded containment domes and various industrial structures. A wind turbine is visible on the left side of the image. The scene is reflected in the calm water in the foreground.

PURPOSE AND OUTLINE OF PRESENTATION



Commission Hearing, April 4, 2018
CMD 18-H6.A

Purpose of CNSC Staff Presentation

- Present to the Commission CNSC staff recommendations with regards to:
 - OPG's request for renewal of Pickering NGS Power Reactor Operating Licence
 - OPG's request to approve operation of Pickering Units 5-8 up to a maximum of 295,000 Effective Full Power Hours



Commission Hearing, April 4, 2018
CMD 18-H6.A

Presentation Outline

- Background
- CNSC Staff Licence Evaluation
- Periodic Safety Review
- End of Commercial Operation
- Performance Assessment
 - Safety and Control Areas (SCAs) ratings
- Regulatory Focus Areas
 - Probabilistic Safety Assessment
 - Fitness for service of fuel channels
 - Radiation Protection
 - Environmental Protection
 - Emergency Preparedness
- Other Matters of Regulatory Interest
- Fuel Channel Operation up to 295,000 Effective Full Power Hours (EFPH)
- Proposed Licence and LCH
- Conclusions and Recommendations

A grayscale photograph of a nuclear power plant facility situated along a body of water. The plant features several large, rounded containment domes and various industrial structures. A wind turbine is visible on the left side of the image. The scene is reflected in the calm water in the foreground. A blue banner with the word 'BACKGROUND' is overlaid on the lower portion of the image.

BACKGROUND




Commission Hearing, April 4, 2018
CMD 18-H6.A

Pickering NGS



- In service within design life
- Refurbished and returned to service
- Safe storage state





Commission Hearing, April 4, 2018
CMD 18-H6.A

Pickering NGS

- Located in City of Pickering
- Generates 14% of Ontario electricity
- Produces Cobalt-60 isotope
- Design developed by AECL
 - Moderated and cooled with heavy water
 - Natural U on-power fueling
 - Inter-connected containment





Commission Hearing, April 4, 2018
CMD 18-H6.A

Important Dates

- Current Pickering NGS Power Reactor Operating Licence expires on August 31, 2018
- OPG has requested the licence to be renewed for a period of 10 years, to August 31, 2028; within the 10-year period:
 - OPG intends to permanently shutdown all reactors by December 31, 2024
 - Following shutdown in 2024, Pickering reactors will begin transition to safe storage

A grayscale photograph of a nuclear power plant at night, with its lights reflecting on the water. A wind turbine is visible on the left side of the plant. The image is used as a background for the title banner.

CNSC STAFF LICENCE EVALUATION



Commission Hearing, April 4, 2018
CMD 18-H6.A

Basis for CNSC Staff Recommendations

- Following receipt of OPG application for Pickering NGS operating licence renewal, CNSC staff assessed:
 - Licence application and supporting information
 - OPG's past performance
 - Other matters of regulatory interest

CMD 18-H6 provides CNSC staff conclusions and recommendations regarding the licence renewal application



Commission Hearing, April 4, 2018
CMD 18-H6.A

Basis for CNSC Staff Recommendations

- CNSC staff assessed the licence renewal application for Pickering NGS to confirm that OPG:
 - Meets applicable legal requirements
 - Implements appropriate regulatory documents and standards
 - Has operating strategy which identifies major challenges and initiatives for the next licensing period

CNSC staff follow established processes for consideration of licence applications



Commission Hearing, April 4, 2018
CMD 18-H6.A

Basis for CNSC staff Recommendations

Pickering compliance regulatory oversight (per Fiscal Year)

Compliance activities effort	2013-14	2014-15	2015-16	2016-17	2017-18 (up to March 2018)
# of Field Inspections	61	71	69	66	65
# of Type II Inspections	32	22	28	26	25
# of Event Report Reviews	139	90	61	59	64
<i>CNSC staff compliance evaluation effort, person-days</i>	6532	6635	7257	7211	5942
<i>CNSC staff licence evaluation effort, person days</i>	1032	561	201	639	2485

CNSC staff maintain adequate compliance oversight effort



Commission Hearing, April 4, 2018
CMD 18-H6.A

Basis for CNSC Staff Recommendations

- CNSC staff review of licensing application follows an established process
- This process
 - Considers licensee's performance against established regulatory framework
 - Is based on modern science and factual evidence
 - Has worked well in the past licensing applications

CNSC builds on proven practices and established a modern and robust regulatory framework

A grayscale photograph of a nuclear power plant at night, with its lights reflecting on the water. A wind turbine is visible on the left side of the plant. The image is slightly faded and serves as a background for the title.

PERIODIC SAFETY REVIEW



Commission Hearing, April 4, 2018
CMD 18-H6.A

Periodic Safety Review (PSR)

- Assessment of current state and performance of plant to determine:
- Extent of conformance to modern codes, standards and practices
- Adequacy and effectiveness of programs, structures, systems and components for continued safe operation
- Opportunities to enhance safety through actions scheduled in Integrated Implementation Plan (IIP)

PSR is a comprehensive assessment leading to practical safety enhancements

Four phases of conducting a PSR





Commission Hearing, April 4, 2018
CMD 18-H6.A

PSR – Integrated Implementation Plan (IIP)


- 63 IIP actions to enhance safe operation, including actions related to
 - Life Cycle Management Plans for the major components
 - Safety analyses impacted by aging
 - Upgrades to ensure containment integrity under severe accidents
 - Condition assessments for piping systems and components for the period of extended operation
- All IIP actions targeted to be completed by end of 2020

CNSC staff thoroughly reviewed and have accepted Pickering IIP



Commission Hearing, April 4, 2018
CMD 18-H6.A

PSR – From 143 Gaps to 63 IIP Actions





Commission Hearing, April 4, 2018
CMD 18-H6.A

PSR – CNSC Staff Conclusions

- OPG performed Pickering PSR in accordance with requirements
- Pickering design, operation, processes and management system will ensure continued safe operation of the station until end of 2024
- IIP actions will enhance the safe operation of the reactor units
- Pickering reactor units will be operated only if fitness for service of the structures, systems and components important to safety is assured

OPG's execution of the IIP will be monitored through CNSC staff regulatory oversight activities

A grayscale photograph of a nuclear power plant at night, with its lights reflecting on the water. A wind turbine is visible on the left side of the plant. The image is slightly faded and serves as a background for the title.


END OF COMMERCIAL OPERATION



Commission Hearing, April 4, 2018
CMD 18-H6.A

End of Commercial Operation (ECO)

- The requested 10-year licence period will include three stages
 - Continued commercial operation to the end of 2024
 - Stabilization activities (e.g., post-shutdown defueling and dewatering)
 - Beginning of safe storage with surveillance





Commission Hearing, April 4, 2018
CMD 18-H6.A

End of Commercial Operation (ECO)

- Regulatory oversight for End of Commercial Operation
- Licence condition LC 15.4 to impose requirements for ECO activities
- OPG must notify the CNSC no later than December 31, 2022, in case it intends to operate any reactor unit beyond December 31, 2024
- Sustainable Operations Plan (SOP) and Stabilization Activity Plan (SAP)
 - identify unique challenges that will require incremental activities
 - provide resolutions, activities and actions for the identified challenges



Commission Hearing, April 4, 2018
CMD 18-H6.A


End of Commercial Operation (ECO)

- Sustainable Operations Plan will be developed and implemented 5 years prior to the permanent shutdown of any unit
- Stabilization Activity Plan will be developed 3 years prior to the permanent shutdown of any unit and implemented immediately after unit is shut down
- Demonstrate how requirements within all 14 SCAs will continue to be met up to the last day of operation, with emphasis on
 - Long-term workforce planning
 - Human performance
 - Fitness for service of safety significant structures, systems and components



Commission Hearing, April 4, 2018
CMD 18-H6.A

End of Commercial Operation (ECO)



A grayscale photograph of a nuclear power plant at night, with its lights reflecting on the water. A wind turbine is visible on the left side of the plant. The image is slightly blurred and has a soft glow.


PERFORMANCE ASSESSMENT



Commission Hearing, April 4, 2018
CMD 18-H6.A

Safety Performance

- 14 Safety and Control Areas are part of CNSC regulatory framework
- Allow consistent reporting, identification of requirements across types of facilities
- Staff have been reporting to the Commission on performance across 14 SCA in annual Regulatory Oversight Reports





Commission Hearing, April 4, 2018
CMD 18-H6.A

SCA Performance Assessments

SAFETY AND CONTROL AREA	PICKERING RATING			
	2013	2014	2015	2016
Management System	SA	SA	SA	SA
Human Performance Management	SA	SA	SA	SA
Operating Performance	SA	SA	FS	FS
Safety Analysis	SA	SA	FS	FS
Physical Design	SA	SA	SA	SA
Fitness for Service	SA	SA	SA	SA
Radiation Protection	FS	FS	FS	SA
Conventional Health and Safety	SA	SA	FS	FS
Environmental Protection	SA	SA	SA	SA
Emergency Management and Fire Protection	SA	SA	SA	SA
Waste Management	SA	SA	FS	FS
Security	FS	FS	SA	SA
Safeguards and Non-Proliferation	SA	SA	SA	SA
Packaging and Transport	SA	SA	SA	SA
INTEGRATED PLANT RATING	SA	SA	FS	FS



Commission Hearing, April 4, 2018
CMD 18-H6.A

Overall Pickering NGS Safety Performance

- Pickering NGS performance has been satisfactory to fully satisfactory
- OPG implemented and maintained effective programs in all required safety areas
- OPG demonstrated commitment to continuous safety improvements
- Pickering NGS staff is qualified to conduct licensed activities safely

Pickering NGS met or exceeded regulatory requirements

A grayscale photograph of a nuclear power plant facility situated along a body of water. The plant features several large containment domes and various industrial structures. A wind turbine is visible on the left side of the image. The scene is reflected in the calm water in the foreground.

REGULATORY FOCUS AREAS



Commission Hearing, April 4, 2018
CMD 18-H6.A

Probabilistic Safety Assessment (PSA)

- Pickering A and Pickering B compliant with S-294 *Probabilistic Safety Assessment (PSA) for Nuclear Power Plants*, since 2014
- OPG completed implementation of the Risk Improvement Plan, requested by the Commission
- Pickering whole-site PSA completed with accepted concept-level methodology


Pickering PSA results demonstrate positive impact of safety enhancements on predicted risk




Commission Hearing, April 4, 2018
CMD 18-H6.A

Pickering A and B PSA Results

Core Damage Frequency (CDF) Results



Large Release Frequency (LRF) Results



Pickering A & B PSA results meet CDF and LRF Safety Goal Limits of 1 in 10,000 and 1 in 100,000 years respectively


Pickering B PSA results also meet CDF and LRF Targets of 1 in 100,000 and 1 in 1,000,000 years respectively




Commission Hearing, April 4, 2018
CMD 18-H6.A

Pickering Whole-site PSA

Whole Site CDF Results



Whole Site LRF Results



Whole site CDF is less than the single-unit Safety Goal of 1 in 10,000 years

Whole site LRF is less than single-unit Safety Goal of 1 in 100,000 years



Commission Hearing, April 4, 2018
CMD 18-H6.A

Fitness for Service – Aging Management

- Pickering NGS has Life Cycle Management Plans (LCMPs) for all major components
 - Feeders, steam generators and preheaters, fuel channels, civil structures
- LCMPs identify activities to continuously assess component condition and fitness for service
- Aging management of fuel channels discussed under OPG request to operate Units 5-8 fuel channels up to 295,000 EFPH

CMD 18-M4 provides generic information on fuel channel fitness for service



Commission Hearing, April 4, 2018
CMD 18-H6.A

Radiation Protection


- Pickering NGS's performance rating decreased in 2016 due to non-compliance with requirements for calibration of radiation instruments
- Nevertheless, CNSC oversight activities confirm that OPG
 - Maintains an effective ALARA program
 - Controls doses to workers
 - Effectively manages radiological hazards
- Dose to public from Pickering NGS remained well below regulatory limits

OPG acted on identified instances of non-compliance with requirements



Commission Hearing, April 4, 2018
CMD 18-H6.A

Radiation Protection – Dose Distribution Data



Individual worker doses at Pickering NGS well below limits



Commission Hearing, April 4, 2018
CMD 18-H6.A

CNSC Environmental Assessment

- CNSC Environmental Assessment concluded that public and environment are protected from releases from the facility
 - OPG environmental protection program meets regulatory requirements
 - Pickering Environmental Risk Assessment and Predictive Effects Assessment are consistent with CSA methodology
 - Findings of CNSC and regional independent monitoring programs consistent with OPG results

Environmental Assessment Report considered the following sources of information

Pickering
environmental
protection program

Pickering
Environmental Risk
Assessment

Results of CNSC's
Independent
Environmental
Monitoring Program

Results of Other
Regional Monitoring

Annual Compliance
Reports

Preliminary
Decommissioning
Plan



Commission Hearing, April 4, 2018
CMD 18-H6.A

OPG Pickering Environmental Risk Assessment (ERA)

- In April 2017, OPG submitted updated Pickering site-wide ERA report
- ERA included risk assessments for radiological and non-radiological (hazardous) contaminants of potential concern and physical stressors
- CNSC staff review found the ERA to be consistent with the requirements of CSA standard N288.6-12, *Environmental risk assessments at class 1 nuclear facilities and uranium mines and mills*
- Meaningful adverse ecological and human health effects due to releases to air and water from Pickering NGS are unlikely



Commission Hearing, April 4, 2018
CMD 18-H6.A

Emergency Preparedness

- OPG undertook numerous emergency response enhancements
 - Implemented portable emergency mitigation equipment, on-site and off-site
 - Distributed potassium iodide pills
 - Installed automated near boundary gamma monitoring system
 - Implemented real-time automatic data transfer to CNSC
 - Developed new computer code for accidental dose projections
 - Installed new radio system
 - Updated public evacuation time estimates



Commission Hearing, April 4, 2018
CMD 18-H6.A

Emergency Preparedness

- Exercise Unified Control, December 6-7, 2017
 - Test of capacity of on-site groups and off-site agencies to respond to a nuclear emergency
 - Response to a severe accident, including the use of portable emergency mitigation equipment added post-Fukushima accident
 - CNSC staff evaluated OPG's performance during the exercise
- OPG annually conducts emergency drills and exercises
- Full-scale integrated exercises required every 3 years



Commission Hearing, April 4, 2018
CMD 18-H6.A

Emergency Preparedness

- Provincial Nuclear Emergency Response Plan (PNERP) revised December 2017
- Included public consultation period
 - CNSC and OPG provided comments to the Province
 - CNSC assisted the Province with simulation of accident scenarios
 - OPG will enhance its emergency plan to align with new PNERP
- Revised PNERP aligns well with the current international recommendations and best practices
- Province targeting to update its Pickering Implementation Plan by end of March 2018

Province taking steps to enhance emergency response



Commission Hearing, April 4, 2018
CMD 18-H6.A

Emergency Preparedness

- CNSC and Canadian Industry, along with the international community took lessons from Fukushima accident to heart, to make sure that such an event would be extremely unlikely at Canadian facilities
- Multiple modifications made to make the probability of severe events very low
- Nevertheless, capability to respond to such events is also made more robust

OPG continues to maintain a robust emergency preparedness program at Pickering NGS

A grayscale photograph of a nuclear power plant facility situated along a body of water. The plant features several large, rounded containment domes and various industrial structures. A wind turbine is visible on the left side of the frame. The lights of the plant are reflected on the water's surface.

OTHER MATTERS OF REGULATORY INTEREST



Commission Hearing, April 4, 2018
CMD 18-H6.A

Other Matters of Regulatory Interest



OUTREACH, PUBLIC
CONSULTATION AND
PARTICIPANT
FUNDING PROGRAM

FIRST NATIONS
AND MÉTIS
ENGAGEMENT



IAEA OSART
MISSION

FISHERIES ACT
AUTHORIZATION



FUKUSHIMA
FOLLOW UP





Commission Hearing, April 4, 2018
CMD 18-H6.A

Outreach, Public Consultation and Participant Funding Program

- Communication via written and electronic notifications, feature articles, graphic updates to web, open houses and social media
- Notice of Public Hearing and Participant Funding issued September 2017
- Up to \$100,000 made available through the Participant Funding Program (PFP)
- Ten recipients awarded up to \$112,962.35 based on recommendations from an independent Funding Review Committee



Commission Hearing, April 4, 2018
CMD 18-H6.A

First Nations and Métis Engagement

- Pickering NGS lies within traditional territories of the seven Williams Treaties First Nations (WTFN) and is of interest to three other First Nations, three First Nations regional representative bodies and Métis Nation of Ontario (MNO) Region 8
- Letters of information sent October 2017, followed-up with phone calls and emails
- Information sharing meetings held upon request with the WTFN, Mississauga's of the New Credit and MNO Region 8
- First Nations, First Nations regional representative bodies and MNO Region 8 were also invited to the CNSC Open House held on March 8, 2018

CNSC staff continue to engage with First Nations and Métis peoples to build positive long-term relationships



Commission Hearing, April 4, 2018
CMD 18-H6.A

Operational Safety Review Team (OSART) Mission

- On request from CNSC, in 2016 IAEA evaluated Pickering NGS operational safety performance against IAEA safety standards
- OSART mission identified 8 good practices, 11 suggestions and 10 recommendations
- OPG has completed 85% of corrective actions to date, with remainder targeted for Q2 2018
 - Managing alcohol and drug use testing of key staff in safety important roles

CNSC staff confirmed that Pickering NGS remained compliant with Canadian regulatory requirements



Commission Hearing, April 4, 2018
CMD 18-H6.A

Fisheries Act Authorization

- *Fisheries Act* requires offsets for any residual harm caused to fish and fish habitats, after mitigation measures have been put in place.
- In July 2017, OPG submitted an application to Fisheries and Oceans Canada (DFO) for an authorization under paragraph 35(2) of the *Fisheries Act*
- DFO authorization issued for Pickering NGS in January 2018 and is valid until December 2028
 - Specifies mitigating and offset measures



Commission Hearing, April 4, 2018
CMD 18-H6.A

Fukushima Action Plan Follow Up

- All original Fukushima Action Items were closed for Pickering
- Re-assessed during Periodic Safety Review (PSR)
 - With the aim to determine whether closure remained valid in context of extended operation
- PSR identified actions to strengthen provisions for controlled filtered venting
 - Part of PSR Integrated Implementation Plan
 - Will be completed by 2020



Commission Hearing, April 4, 2018
CMD 18-H6.A

Fukushima Action Plan Follow Up

- OPG modifications to protect containment integrity:
 - Interconnections to add water to steam generators, heat transport system and calandria
 - Power and support service connections required to restore functionality of main volume vacuum pump
 - Emergency power and cooling water to air conditioning units
 - Redundant emergency power supply to hydrogen igniters and filtered air discharge system
 - Equipment and procedures to strengthen filtered air discharge system



Commission Hearing, April 4, 2018
CMD 18-H6.A

Fukushima Action Plan Follow Up

- OPG has implemented and will continue to implement physical and programmatic changes to:
 - Strengthen provisions to prevent progression of an initiating event to a severe accident
 - Prevent and mitigate challenges for containment integrity
 - Ensure availability of options for controlled filtered post-accident venting

Pickering will implement additional measures to prevent containment challenges

A grayscale photograph of a nuclear power plant at night, with various structures and lights visible. A large blue banner is overlaid on the bottom half of the image.

FUEL CHANNEL OPERATION TO 295,000 EFPH



Commission Hearing, April 4, 2018
CMD 18-H6.A

Units 5-8 operation up to 295,000 EFPH

- OPG is requesting approval to operate Units 5-8 up to a maximum of 295,000 Effective Full Power Hours (EFPH)
 - Current limit is 247,000 EFPH and hydrogen concentration of 120 parts per million
 - Periodic Inspections Program
- OPG implemented measures to maintain Fuel Channel Fitness for Service
 - Periodic Inspections Program
 - Internal and external operating experience
 - Research and Development and Joint industry projects



Commission Hearing, April 4, 2018
CMD 18-H6.A

Units 5-8 operation up to 295,000 EFPH

- Fuel Channel performance can be affected by several degradation mechanisms
 - Some are relatively innocuous (e.g. pressure tube crevice corrosion)
 - Some progress at a predictable rate, with no known cliff-edge effect (e.g. fuel channel elongation)
 - Some could be life limiting (e.g. reduction in pressure tube fracture toughness with increasing hydrogen content)

Satisfactory understanding of fuel channel degradation mechanisms for all Pickering Units



Commission Hearing, April 4, 2018
CMD 18-H6.A

Units 5-8 operation up to 295,000 EFPH

- CNSC staff recommend the Commission approve operation of Pickering Units 5-8 up to a maximum of 295,000 EFPH, based on
 - Pickering fuel channels are not expected to reach [Heq] of 120 parts per million before the end of operation at 295,000 EFPH
 - Adequate safety margins will be maintained
 - Strong knowledge of degradation mechanisms
 - Effective inspection and monitoring program
- New licence condition with appropriate compliance verification criteria should predictions of [Heq] be revised to exceed 120 ppm

A grayscale photograph of a nuclear power plant at night, with its lights reflecting on the water. A wind turbine is visible on the left side of the plant. The image is slightly blurred and has a soft glow.

PROPOSED LICENCE AND LCH



Commission Hearing, April 4, 2018
CMD 18-H6.A

Proposed Licence and Licence Conditions Handbook

- Power Reactor Operating Licence (PROL)
 - Describes the licensed activity
 - Set the licence duration
 - Contains licence conditions
- Proposed Licence Conditions Handbook (LCH)
 - Describes Compliance Verification Criteria for each licence condition
 - Identifies CNSC Regulatory Documents and Canadian Standards
 - Provides Guidance



Commission Hearing, April 4, 2018
CMD 18-H6.A

Standardized Wording of Licence Conditions (LC)

- Standardized wording to allow consistent use of LCs across all Class I Nuclear Facilities
- Requires licensees to implement and maintain programs as approved by the Commission and described in the LCH
- Requires licensees to operate within the licensing basis
- Requires licensees to notify CNSC of any changes which may impact operation within the licensing basis

Standardized licence conditions cover all 14 SCAs



Commission Hearing, April 4, 2018
CMD 18-H6.A

Proposed Licence Period

- CNSC staff are recommending a 10 year licence period based on:
 - Stable safety performance of OPG
 - Outcomes of Periodic Safety Review and resulting Integrated Implementation Plan actions
 - Strategy for managing end of commercial operation and transition to safe storage

*Annual presentation of regulatory oversight results to
Commission allows for ongoing reporting and public input*



Commission Hearing, April 4, 2018
CMD 18-H6.A

Licence Condition Handbook CNSC Regulatory Documents

25 Regulatory Documents

- 18 unchanged
- 4 updated
- 3 new

*No reduction in regulatory
requirements*

New and Updated Regulatory Documents

New: REGDOC-2.2.4 Fitness for Duty: Managing Worker Fatigue

New: REGDOC-2.3.2 Accident Management (2013)

New: REGDOC-2.3.3 Periodic Safety Reviews

Updated: REGDOC-2.6.3 Aging Management

Updated: REGDOC-2.9.1 Environmental Protection (2013)

Updated: REGDOC-2.10.1 Nuclear Emergency Preparedness and Response (2016)

Updated: RD/GD – 210 Maintenance Programs



Commission Hearing, April 4, 2018
CMD 18-H6.A

Licence Condition Handbook CSA Standards

25 CSA standards

- 9 unchanged
- 5 updated
- 11 new

*No reduction in regulatory
requirements*

Examples of New CSA Standards

New: N290.12-14 Human factors in design for NPPs

New: N287.1-14 and N287.2-08 General /Material requirements for concrete containment structures for NPPs

New: N291-08 Requirements for safety-related structures for CANDU NPPs

New: N289.1-08 General requirements for seismic design and qualification of CANDU NPPs

New: N288.3.4-13 Performance testing of nuclear air-cleaning systems at nuclear facilities

New: N288.5-11 Effluent monitoring programs at Class I nuclear facilities and uranium mines and mills

New: N288.6-12 Environmental risk assessments at Class I nuclear facilities and uranium mines and mills

A grayscale photograph of a nuclear power plant facility situated along a body of water. The plant features several large, rounded containment domes and various industrial structures. A wind turbine is visible on the left side of the image. The scene is reflected in the calm water in the foreground.

CONCLUSIONS AND RECOMMENDATIONS



Commission Hearing, April 4, 2018
CMD 18-H6.A

Conclusions

With respect to section 24(4) of the NSCA, CNSC staff conclude:

- OPG is qualified to carry on the activities authorized by the licence; and
- In carrying out the licensed activities, OPG has made, and will continue to make adequate provision for the protection of the environment, the health and safety of persons and the maintenance of national security and measures required to implement international obligations to which Canada has agreed



Commission Hearing, April 4, 2018
CMD 18-H6.A

Recommendations (1/2)

CNSC staff recommend that the Commission:

1. Renew the Pickering licence to authorize OPG to carry out the activities listed in Part IV of the licence, from September 1, 2018 to August 31, 2028
2. Authorize OPG to operate Pickering NGS Units 5-8 up to a maximum of 295,000 EFPH
3. Authorize delegation of authority for a person authorized by the Commission for
 - LC 3.2 - restart after a serious process failure



Commission Hearing, April 4, 2018
CMD 18-H6.A

Recommendations (2/2)

4. Accept the station-specific conditions included in proposed PROL requiring OPG to:
 - Implement the Integrated Implementation Plan actions
 - Maintain Units 2 and 3 in a safe storage state
 - Maintain pressure tube fracture toughness sufficient for safe operation
 - Implement and maintain plans for the end of commercial operation
 - Implement and maintain a Cobalt 60 program
 - Limit the activities of import and export of nuclear substances to those occurring as contaminants in laundry, packaging, shielding or equipment

Connect With Us



nuclearsafety.gc.ca

